

POOL GAS ELECTRICAL AND COMMUNICATIONS

DRAFT



CHECK FIELD PROJECT FOR COPPER & FIBER

ABANDONED CABINET IN EACH PORTABLE NEEDS TO BE REMOVED

NEEDS NEW CONDUIT INFRASTRUCTURE

LIGHTS GOT BROKEN

LIGHT OUT

BAD WIRING FOR POLE LIGHT

E7: IDF IN E5, E6 & E8 ??

Z1:CHK MOD DESIGN FOR IDF

NEW MARQUEE PART OF I&U MOD?

CHECK MOD DESIGN

- NOTES:**
1. NO POWER @ ENTRY COURT UNDER GROUND LIGHT FEED FROM "R"
 2. LOWER ALL DATA CABINETS THAT HANG UP HIGH
 3. REMOVE UPS FROM ALL CABINETS THAT HANG ON THE WALLS
 4. PROVIDE LEARNING SPACES IN THE FIELDS
 5. PROVIDE CAMERAS IN THE FIELDS
 6. PROVIDE DATA AND POWER TO TRACK AND FIELDS
 7. UPGRADE EXISTING INTRUSION SYSTEM

- LEGEND:**
- (RED) ELECTRICAL
 - (ORANGE) COMMUNICATION
 - (YELLOW) GAS
 - ER ELECTRICAL ROOM
 - TC TIME CLOCK
 - MAIN BREAKER
 - TRANSFORMER
 - IDF/MDF/MPOE
 - BLD GAS SHUTT OFF VALVE (SOV)

OAK GROVE