

WATER IRRIGATION STORM DRAIN SEWER

DRAFT



GREASE TRAP NEEDS TO BE REPLACED

STORM DRAIN ISSUE NEED TO LOOK AT

UNDERGROUND CREEK BY SSCWD (GOFER PIPE)

SEWER IN PUMP SYSTEM

FLOODING BY GRADING

FLOODING BY GRADING

REVIEW STORM DRAIN & GRADING SYSTEM

- NOTES:**
1. HALL WAY R/R - NO VALVE, NEED TO SHUT DOWN CAMPUS
 2. MAIN LINE - STEEL; MANY ISSUES WITH LINE (LEAKS): BAND CLAMP REPLACEMENT
 3. IRR LINE - TRANSITE/PVC NEED TO REPLACE TRANSITE

LEGEND:

(BLUE)	DOMESTIC WATER
(PURPLE)	RECLAIMED IRRIGATION
(GREEN)	SANITARY/STORM DRAIN (SS) (SD)
DW	DOMESTIC WATER
FP	FIRE PROTECTION
IW	IRRIGATION WATER
POC	POINT OF CONNECTION
DF	DRINKING FOUNTAIN (DF)
SOV	SHUT OFF VALVE (SOV)
IC	IRRIGATION CONTROLLER (IC)
BFP	BACK FLOW PREVENTER (BFP)
QC	QUICK COUPLER (QC)
FH	FIRE HYDRANT
PIV	POST INDICATOR VALVE
CB	CATCH BASIN

PIEDMONT HILLS